

Visitability Checklist

Date: _____

Inspector Name: _____

Required standards for building type:

Toledo Municipal Code-1347

Fair Housing Guidelines

One-, Two-, Three-, Family dwellings

*Includes Multifamily and new construction sites with OHFA Funds

	Residential Requirements	Observations/Comments/ Suggestions
Exterior	<ul style="list-style-type: none"> <input type="checkbox"/> At least 1 no step entrance on visitable route <input type="checkbox"/> Any accessible routes under 5% <input type="checkbox"/> Ramps between 5%-8.33% slope have handrails and edge protectio 	
Doors, Entryways, Hallways	<ul style="list-style-type: none"> <input type="checkbox"/> Doors have a minimum net clearing of 32" <input type="checkbox"/> Hallways on main floor have width minimum of 36" <input type="checkbox"/> Thresholds no more than ¼" high 	
Bathroom	<ul style="list-style-type: none"> <input type="checkbox"/> Provides at least 1 full or half bath on main floor <input type="checkbox"/> Bathroom has clear space of 30"x48" <input type="checkbox"/> Walls in bathroom have blocking for grab bars 	
Living Space	<ul style="list-style-type: none"> <input type="checkbox"/> Clear path throughout 	
Functionality/ Environmental Controls	<ul style="list-style-type: none"> <input type="checkbox"/> Wall outlets placed at least 15" from the finished floor <input type="checkbox"/> Environmental controls placed no higher than 48" above the floor. 	
Public Access and Common Spaces <ul style="list-style-type: none"> ● Accessible routes include: a firm and slip resistant floor, width of 36" min., running slope 5% ,max., and cross slope 2% max. Ramps and curb ramps for access, a clear turning space and passing spaces of 60" width if route width is less than 60" (ADA 403). 	<ul style="list-style-type: none"> <input type="checkbox"/> Accessible route to rental office from parking lot <input type="checkbox"/> Accessible route from public right-of-way <input type="checkbox"/> Common Areas observed (Pool, clubhouse, fitness room, laundry room)? Please note if accessible route and entrance was observed 	
Parking - <ul style="list-style-type: none"> ● For a rental office: if parking facility is 1-25 spaces, 1 accessible space. If 26-50 spaces, 2 accessible spaces needed. ● For residential parking areas: If 1 space is reserved for residents, 1 accessible space for each accessible unit. If more than 1 space for residents, 2% of all spaces must be accessible spaces. ● For every six accessible spaces, 1 must be a van space. (ADA 208). 	<ul style="list-style-type: none"> <input type="checkbox"/> Designated accessible parking spaces for rental office, with adjacent access aisle <input type="checkbox"/> Resident accessible car parking space of 96" <input type="checkbox"/> Resident van accessible parking space of 132" <input type="checkbox"/> Access aisle of 60" <p>*note: if access aisle is 96" then van parking can be 96"</p>	